

RFI

Today's Date: 8/28/2017

RFI #: 01

From: Post Earthworks Constructors

To: Construct one

Information Requested: Grinding of Asphalt

Can the demo/earthwork contractor grind the existing asphalt and base and use as on-site fill under hard scape?

Response:

From a geotechnical standpoint, the existing Asphalt Concrete and Aggregate Base can be grinded and placed as compacted material under hardscape areas.

Raul R. Garcia, PE, GE | Senior Engineer
Geocon Incorporated
8/30/174