

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**Central High School West Water System
Has Levels of Hexavalent Chromium Above Drinking Water Standards**

Water produced by our water system failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Results of water samples collected over the last year show an average hexavalent chromium concentration of 16 in Existing Well, and N/A in New Well. These averages are above the standard or maximum contaminant level (MCL) of 0.010 mg/L or 10 ug/L.

What should I do?

- You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.
- *This is not an emergency. If it had been, you would have been notified immediately. However, some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer*
- If you have other health issues concerning the consumption of this water, you may wish to consult a doctor.

What happened? What was done?

(Describe corrective action): Subsequent sampling public notification
We anticipate resolving the problem within [estimated time frame] _____
For more information, please contact James Dargatzis [insert name of contact] at
430-5833 [insert phone number] or at the following mailing address:
4877r W. Jennifer suite 104 Fresno 93722 [insert mailing address].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by
Central High School West -- State Water System No. 1000217

Date distributed 4-20-17

Certification of Completion of Public Notification

This form, when completed and returned to the Division of Drinking Water - Fresno District (265 W. Bullard Ave. #101, Fresno, CA 93704 or fax to 559-447-3304), serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public Water System Name: Central High School West

Public Water System No.: 1000217

Public notification for failure to comply with the Hexavalent Chromium MCL for the quarter of 20 was performed by the following method(s) (check and complete those that apply):

The notice was mailed to users on: _____
 A copy of the notice is attached.

The notice was hand delivered to water customers on: 5/17/17
 A copy of the notice is attached.

The notice was published in the local newspaper on: _____
 A copy of the newspaper notice is attached.

The notice was published in conspicuous places on: _____
 A copy of the notice is attached.
 A list of locations the notice was posted is attached.

The notice was delivered to community organizations on: _____
 A copy of the notice is attached.
 A list of community organizations the notice was delivered to is attached.

I hereby certify that the above information is factual.

John Schweidt
Printed Name

operator
Title

John Schweidt
Signature

5/17/17
Date

Disclosure: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation each day that the violation continues. In addition, the violators may be prosecuted in criminal court and, upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due to the Division of Drinking Water within 10 days of issuance of notice to customers
System Number: 1000217
Enforcement Action No. 03-23-15R-003

Quarterly Progress Report

Water System: Central High School West	Water System No.: 1000217
Compliance Order No.: 03-23-15R-009	Violation: Hexavalent Chromium MCL
Calendar Quarter: 2ND	Date Prepared: 5-17-17

This form should be prepared and signed by Water System personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The quarterly progress report must be submitted by the 10th day of each subsequent quarter, to the Division of Drinking Water, Fresno District Office.

Summary of Compliance Plan:

- DISTRICT INTENDS ON CONSOLIDATING CENT. H.S. WITH CENT. WEST ARCS SYSTEMS AND UTILIZING ADDITIONAL SUPPLY WELLS

Tasks completed in the reporting quarter:

PUBLIC NOTIFICATION TO CONSUMERS -
& CONTINUED QUARTERLY MONITORING FOR HEXAVALENT CHROMIUM

Tasks remaining to complete:

INVESTIGATE TREATMENT TECHNOLOGIES IF NECESSARY AUTHORIZED BY SCHOOL DISTRICT

Anticipate compliance date: 2017-

James Derby

Name

James B

Signature

@P WATER SUPERVISOR

Title

5-17-17

Date