


Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Fullerton, City of
303 W. Commonwealth Ave.
Fullerton CA, 92832

Project: School Lead Program
Sub Project: Lead Sampling for FSD / Acacia Elementary
Project Manager: Don Davenport

Work Order: 18A1662
Received: 01/17/18 16:55
Reported: 01/26/18

3010010-AAI-A 18A1662-01 (Water) Sample Date: 01/17/18 6:21 Sampler: Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

3010010-AAI-B 18A1662-02 (Water) Sample Date: 01/17/18 6:27 Sampler: Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

3010010-AAI-C 18A1662-03 (Water) Sample Date: 01/17/18 6:31 Sampler: Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

3010010-AAI-D 18A1662-04 (Water) Sample Date: 01/17/18 6:37 Sampler: Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

3010010-AAI-E 18A1662-05 (Water) Sample Date: 01/17/18 6:41 Sampler: Not Listed

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals


Lead (Pb) SM3113-B ND 5.0 15 ug/L 01/23/18 01/25/18 1804036

ND Analyte NOT DETECTED at or above the reporting limit

Stu Styles
Client Services Manager

Clinical Laboratory of San Bernardino, Inc.

EDT Transfer Confirmation 1



Work Order: 18A1662

Report Date: 01/26/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

Page 1 of 1

CITY OF RIVERSIDE	User ID: TEE	System: 3010010
Acacia Elementary-Outdoor Drinking Fo	Station No.: 3010010-AAI-A	Sampled: 180117 06:21
LEAD	Result: ND Units: UG/L	Entry No.: 01051 Analyzed: 180125
Acacia Elementary-Playground Drinking	Station No.: 3010010-AAI-B	Sampled: 180117 06:27
LEAD	Result: ND Units: UG/L	Entry No.: 01051 Analyzed: 180125
Acacia Elementary-Partition 4 Hallway	Station No.: 3010010-AAI-C	Sampled: 180117 06:31
LEAD	Result: ND Units: UG/L	Entry No.: 01051 Analyzed: 180125
Acacia Elementary-Partition 5 Drinkin	Station No.: 3010010-AAI-D	Sampled: 180117 06:37
LEAD	Result: ND Units: UG/L	Entry No.: 01051 Analyzed: 180125
Acacia Elementary-Partition 5 Drinkin	Station No.: 3010010-AAI-E	Sampled: 180117 06:41
LEAD	Result: ND Units: UG/L	Entry No.: 01051 Analyzed: 180125

