

Mr. William Mercantini  
Board President

Mr. Joshua Fausti  
Board Vice President

# Bordentown Regional School District

318 WARD AVENUE  
BORDENTOWN, NJ 08505

Dr. Edward J. Forsthoffer III  
Superintendent

Mr. Eloi A. Richardson, CPA  
Business Administrator

<b>Business Office</b> (609) 298-0025 Extension 1204	<b>FAX</b> (609) 298-2515	<b>Superintendent's Office</b> (609) 298-0025 Extension 1211
------------------------------------------------------------	------------------------------	--------------------------------------------------------------------

Internet Web Site: [www.bordentown.k12.nj.us](http://www.bordentown.k12.nj.us)

January 25, 2017

Dear Clara Barton Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, the Bordentown Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Clara Barton Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

## Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the Bordentown Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 64 samples taken, all but 18 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action the Bordentown Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
Kitchen Ice Machine	23.7	Posted Signage "DO NOT DRINK"
Classroom 136	133	Temporarily disconnected pending further testing
Classroom 123	24	Temporarily disconnected pending further testing

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
Classroom 123	20.9	Temporarily disconnected pending further testing
Faculty Room	318	Temporarily disconnected pending further testing
Classroom 110	16.1	Temporarily disconnected pending further testing
Classroom 107	75.1	Temporarily disconnected pending further testing
Classroom 221	225	Temporarily disconnected pending further testing
Classroom 221	60.5	Temporarily disconnected pending further testing
Classroom 223	92	Temporarily disconnected pending further testing
Classroom 216	246	Temporarily disconnected pending further testing
Classroom 215	26.1	Temporarily disconnected pending further testing
Classroom 206	17.7	Temporarily disconnected pending further testing
Classroom 207	28.1	Temporarily disconnected pending further testing
Classroom 209	36.3	Temporarily disconnected pending further testing
Classroom 260	27.1	Temporarily disconnected pending further testing
Classroom 260	28.1	Temporarily disconnected pending further testing
Classroom 260	58.2	Temporarily disconnected pending further testing

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and

developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even

cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water


Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available at the Clara Barton Elementary School and can be viewed between the hours of 8:00 a.m. and 3:30 p.m. and are also available on our website at [www.bordentown.k12.nj.us](http://www.bordentown.k12.nj.us). For more information about water quality in our schools, contact Eloi Richardson, Business Administrator, 609-298-0025 (ext. 1204).

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.



Dr. Edward J. Forstoffer III

