



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: BF

Fred Hauck  
20104 NYS Route 3  
Watertown, NY 13601

Project / PO Number: N/A  
Received: 10/17/2016 15:00  
Reported: 12/27/2016 16:55

Analytical Testing Parameters

Client Sample ID: 45  
Lab Sample ID: J6J1258-01  
Sample Type: Grab

Collected By: LS-Client  
Collection Date: 10/14/16  
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0036	0.015	0.001	mg/L		12/14/16 1019	12/16/16 1156

Analytical Testing Parameters

Client Sample ID: 76  
Lab Sample ID: J6J1258-02  
Sample Type: Grab

Collected By: LS-Client  
Collection Date: 10/14/16  
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0061	0.015	0.001	mg/L		12/14/16 1019	12/16/16 1202

Analytical Testing Parameters

Client Sample ID: 77  
Lab Sample ID: J6J1258-03  
Sample Type: Grab

Collected By: LS-Client  
Collection Date: 10/14/16  
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	<0.001	0.015	0.001	mg/L		12/14/16 1019	12/16/16 1204



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 75
Lab Sample ID: J6J1258-04
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.007, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1205

Analytical Testing Parameters

Client Sample ID: 70
Lab Sample ID: J6J1258-05
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1207

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6J1258-06
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0055, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1209



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J6J1258-07
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0058, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1214

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J6J1258-08
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1216

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J6J1258-09
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1218



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J6J1258-10
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0069, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1220

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J6J1258-11
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0054, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1222

Analytical Testing Parameters

Client Sample ID: 74
Lab Sample ID: J6J1258-12
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0048, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1225



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J6J1258-13
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0075, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1227

Analytical Testing Parameters

Client Sample ID: 68
Lab Sample ID: J6J1258-14
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1229

Analytical Testing Parameters

Client Sample ID: 69
Lab Sample ID: J6J1258-15
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0013, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1230



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6J1258-16
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1236

Analytical Testing Parameters

Client Sample ID: 71
Lab Sample ID: J6J1258-17
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:39

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1238

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J6J1258-18
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0049, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1239



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 33
Lab Sample ID: J6J1258-19
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0053, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1241

Analytical Testing Parameters

Client Sample ID: 73
Lab Sample ID: J6J1258-20
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1019, 12/16/16 1243

Analytical Testing Parameters

Client Sample ID: 72
Lab Sample ID: J6J1258-21
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1215, 12/16/16 1353



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 65
Lab Sample ID: J6J1258-22
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0067, 0.015, 0.001, mg/L, 12/14/16 1215, 12/16/16 1358

Analytical Testing Parameters

Client Sample ID: 64
Lab Sample ID: J6J1258-23
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0095, 0.015, 0.001, mg/L, 12/14/16 1215, 12/16/16 1400

Analytical Testing Parameters

Client Sample ID: 67
Lab Sample ID: J6J1258-24
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.011, 0.015, 0.001, mg/L, 12/14/16 1215, 12/16/16 1402





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 66
Lab Sample ID: J6J1258-25
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0058, 0.015, 0.001, mg/L, 12/14/16 1215, 12/16/16 1404

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6J1258-26
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0061, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1406

Analytical Testing Parameters

Client Sample ID: 28
Lab Sample ID: J6J1258-27
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.006, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1411



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J6J1258-28
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0038, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1413

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6J1258-29
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0077, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1415

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J6J1258-30
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0015, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1416



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 61
Lab Sample ID: J6J1258-31
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0011, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1418

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J6J1258-32
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0013, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1422

Analytical Testing Parameters

Client Sample ID: 26
Lab Sample ID: J6J1258-33
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0041, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1424



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 63
Lab Sample ID: J6J1258-34
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0077, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1425

Analytical Testing Parameters

Client Sample ID: 62
Lab Sample ID: J6J1258-35
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0093, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1427

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J6J1258-36
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1433



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6J1258-37
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0055, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1434

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6J1258-38
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0055, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1436

Analytical Testing Parameters

Client Sample ID: 22-1
Lab Sample ID: J6J1258-39
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0038, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1438



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6J1258-40
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.005, 0.015, 0.001, mg/L, 12/14/16 1354, 12/16/16 1440

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6J1258-41
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1449

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6J1258-42
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0037, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1454



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6J1258-43
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1456

Analytical Testing Parameters

Client Sample ID: 23-1
Lab Sample ID: J6J1258-44
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0025, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1458

Analytical Testing Parameters

Client Sample ID: 25
Lab Sample ID: J6J1258-45
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1500



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 94
Lab Sample ID: J6J1258-46
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0043, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1501

Analytical Testing Parameters

Client Sample ID: 95
Lab Sample ID: J6J1258-47
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0076, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1507

Analytical Testing Parameters

Client Sample ID: 96
Lab Sample ID: J6J1258-48
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0076, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1509





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 24-2
Lab Sample ID: J6J1258-49
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0011, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1510

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6J1258-50
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1512

Analytical Testing Parameters

Client Sample ID: 24-1
Lab Sample ID: J6J1258-51
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.004, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1514



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 23-2
Lab Sample ID: J6J1258-52
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1517

Analytical Testing Parameters

Client Sample ID: 22-2
Lab Sample ID: J6J1258-53
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1519

Analytical Testing Parameters

Client Sample ID: 56
Lab Sample ID: J6J1258-54
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0027, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1521



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 92
Lab Sample ID: J6J1258-55
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0079, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1523

Analytical Testing Parameters

Client Sample ID: 88
Lab Sample ID: J6J1258-56
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0088, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1528

Analytical Testing Parameters

Client Sample ID: 91
Lab Sample ID: J6J1258-57
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.008, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1530



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 90
Lab Sample ID: J6J1258-58
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0078, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1532

Analytical Testing Parameters

Client Sample ID: 57
Lab Sample ID: J6J1258-59
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0044, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1534

Analytical Testing Parameters

Client Sample ID: 89
Lab Sample ID: J6J1258-60
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0048, 0.015, 0.001, mg/L, 12/14/16 1432, 12/16/16 1535



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 58
Lab Sample ID: J6J1258-61
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.002, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1545

Analytical Testing Parameters

Client Sample ID: 8
Lab Sample ID: J6J1258-62
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0051, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1550

Analytical Testing Parameters

Client Sample ID: 11
Lab Sample ID: J6J1258-63
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0027, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1552



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 55
Lab Sample ID: J6J1258-64
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0059, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1553

Analytical Testing Parameters

Client Sample ID: 93
Lab Sample ID: J6J1258-65
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.01, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1555

Analytical Testing Parameters

Client Sample ID: 87
Lab Sample ID: J6J1258-66
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0053, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1557



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 59
Lab Sample ID: J6J1258-67
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:29

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0063, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1602

Analytical Testing Parameters

Client Sample ID: 54
Lab Sample ID: J6J1258-68
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.006, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1604

Analytical Testing Parameters

Client Sample ID: 86
Lab Sample ID: J6J1258-69
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0019, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1606



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 12
Lab Sample ID: J6J1258-70
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0021, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1608

Analytical Testing Parameters

Client Sample ID: 47
Lab Sample ID: J6J1258-71
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0019, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1610

Analytical Testing Parameters

Client Sample ID: 84
Lab Sample ID: J6J1258-72
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0071, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1613





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 46
Lab Sample ID: J6J1258-73
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0086, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1615

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J6J1258-74
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1617

Analytical Testing Parameters

Client Sample ID: 9
Lab Sample ID: J6J1258-75
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0046, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1619



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 51
Lab Sample ID: J6J1258-76
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:18

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1624

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J6J1258-77
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0017, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1626

Analytical Testing Parameters

Client Sample ID: 5
Lab Sample ID: J6J1258-78
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1628



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J6J1258-79
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0066, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1629

Analytical Testing Parameters

Client Sample ID: 6
Lab Sample ID: J6J1258-80
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0015, 0.015, 0.001, mg/L, 12/14/16 1504, 12/16/16 1631

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J6J1258-81
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:03

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0042, 0.015, 0.001, mg/L, 12/14/16 1532, 12/20/16 2048



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 2
Lab Sample ID: J6J1258-82
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:04

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0059, 0.015, 0.001, mg/L, 12/14/16 1532, 12/20/16 2053

Analytical Testing Parameters

Client Sample ID: 80
Lab Sample ID: J6J1258-83
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0013, 0.015, 0.001, mg/L, 12/14/16 1532, 12/20/16 2055

Analytical Testing Parameters

Client Sample ID: 13
Lab Sample ID: J6J1258-84
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0044, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1430



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 97 Ice
Lab Sample ID: J6J1258-85
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1435

Analytical Testing Parameters

Client Sample ID: 78
Lab Sample ID: J6J1258-86
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1437

Analytical Testing Parameters

Client Sample ID: 79
Lab Sample ID: J6J1258-87
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0019, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1439



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 81
Lab Sample ID: J6J1258-88
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.018, 0.015, 0.001, mg/L, G, 12/14/16 0745, 12/14/16 1441

Analytical Testing Parameters

Client Sample ID: 17
Lab Sample ID: J6J1258-89
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0054, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1443

Analytical Testing Parameters

Client Sample ID: 82
Lab Sample ID: J6J1258-90
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0057, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1448



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 44
Lab Sample ID: J6J1258-91
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.005, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1450

Analytical Testing Parameters

Client Sample ID: 15
Lab Sample ID: J6J1258-92
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:08

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.009, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1452

Analytical Testing Parameters

Client Sample ID: 18
Lab Sample ID: J6J1258-93
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.018, 0.015, 0.001, mg/L, G, 12/14/16 0745, 12/14/16 1453



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 4
Lab Sample ID: J6J1258-94
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0029, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1455

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J6J1258-95
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:03

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.003, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1459

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J6J1258-96
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0013, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1501





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 83
Lab Sample ID: J6J1258-97
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0021, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1502

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J6J1258-98
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0018, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1504

Analytical Testing Parameters

Client Sample ID: 85
Lab Sample ID: J6J1258-99
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0076, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1510



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J6J1258-AA
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0024, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1511

Analytical Testing Parameters

Client Sample ID: 14
Lab Sample ID: J6J1258-AB
Sample Type: Grab

Collected By: LS-Client
Collection Date: 10/14/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, MCL, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0026, 0.015, 0.001, mg/L, 12/14/16 0745, 12/14/16 1513

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
G: Result fails applicable NYS drinking water standards
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. Dayville (NY 11549) NY Lab ID No: 11549 New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1258

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield  
Division Manager  
12/27/2016 16:55

**Go Green:** Contact Michael Fifield to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

**Microbac Laboratories, Inc. Samples must be returned on ice**  
**CHAIN OF CUSTODY**

BF

MNY Workorder #



J6J1258

Client Information		Billing/Invoice:		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES NO	Accepted?	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container Material	
Contact:	Watertown, NY 13601			Sample Temp:		Container Size (in Mi)	
Phone:	Ray Filley			Cooler Seal:	YES NO	Preservative	
Project:	Lead Testing			Pickup:	YES NO	Comments/Field Data	
Quote ID:		PO#:		Dropoff:	C W		
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req:					
Release to DOH: Yes							
Email Results: Yes	rfilley@boces.com / fhauck@boces.com						
Fax Results: Yes							

Sample Information		Matrix		Number of Containers for Analytix Requested		Date/Time	
Description/Location	Date	Time	Initial	Type			Signature
1 45	10/14	655	LS				
2 76		650					
3 77		643					
4 75		650					
5 70		639					
6							
7							
8							

Print Name and Company	Date/Time	Comments
Sampled: LINDA SHAW	10/17 1200	
Received: D. Biechele	10-17-1500	
Received:		
Received:		
Received:		
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

3621 Buck Drive  
 Cortland NY 13045  
 Phone: (607) 753-3403 Fax: (607) 753-3416  
 NY #10786, EPA #NY00935

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

MNY Workorder #

Client Information				Billing/Invoice:			
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		Address: 20104 NYS Route 3		Waterdown, NY 13601		Contact: Ray Filley	
Phone: 315-779-7054		Project: Lead Testing		Quote ID:		PO#:	
Rush TAT Bur. Days: < 2-5 5-7 7-10		Date Req:		Release to DOH: Yes		Email Results: Yes	
Fax Results: Yes		rfiley@boces.com / rfiley@boces.com		Matrix Type		Number of Containers for Analysis Requested	
Sample Information				Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Comments	Receiving Info (Lab Use Only)
1 38	10/14	647	LS				Ice: YES NO Cooler: YES NO Sample Temp: YES NO Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size (in MI) Preservative
2 37		647					
3 40		647					
4 39		647					
5 42		649					
6 43		649					
7 74		650					
8 41		649					
Print Name and Company				Signature			
Sampled: LINDA SHAW				Date/Time: 10/17/1200			
Received: DBrechele				Date/Time: 10-17/1500			
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3621 Buck Drive  
 Cortland NY 13046  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10796, EPA #NY00936

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req:	
Relate to DOH: Yes			
Email Results: Yes	rfilley@boces.com / fhawck@boces.com		
Fax Results: Yes			
Sample Information			
Description/Location	Date	Time	Initial
1 608	10/14	608	LS
2 609		608	
3 335		605	
4 71		609	
5 34		605	
6 33		603	
7 73		603	
8 72		603	
Matrix Type		Date/Time	
200.8 Lead		10/17 1200	
P		10/17/1500	
250			
HNO3			
Sample Information		Signature	
Print Name and Company		LINDA SHAW	
Received:		D Brechele	
Received:			
Received:			
Received:			
Received:			
Receiving Info (Lab Use Only)		Comments	
Ice:	YES NO		
Cooler:	YES NO		
Sample Temp:			
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	YES NO		
Container Material:			
Container Size(In MI)			
Preservative:			
Comments/Field Data			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Run/TAT Bus. Days:	2-5 5-7 7-10					Accepted:	YES NO
Release to DOH:	Yes					Container Material:	
Email Results:	Yes					Container Size (in MI):	
Fax Results:	Yes					Preservative:	
	filley@boces.com / fhack@boces.com					Comments/Field Data	
	200.8 Lead						
	P						
	250						
	HNO3						
Sample Information		Number of Containers for Analysis Requested		Date/Time		Comments	
Description/Location	Date	Time	Initial	Matrix Type			
1 605	10/14	6033	LS				
2 604		6033					
3 607		6034					
4 606		6034					
5 30		6036					
6 28		6034					
7 31		6037					
8 29		6036					
Sampled:	LINDA SHAW			Signature			
Received:	D. Beche			Date/Time	10/17/10		
Received:				Date/Time	10-17-10		
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this practice.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10796, EPA #NY00936

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Otsego BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10	Date Req:	
Release to DOH:	Yes		
Email Results:	Yes	filley@boces.com / rhauck@boces.com	
Fax Results:	Yes		

Sample Information			Analytix Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Matrix Type	Accepted?	Container Material
1 600	10/14	626	LS		YES	NO
2 601		626			YES	NO
3 27		631			YES	NO
4 26		629			C	W
5 603		637			YES	NO
6 602		632				
7 36		645				
8 32		637				

Print Name and Company	Signature	Date/Time	Comments
Sampled: LAURA SHAW	<i>[Signature]</i>	10/17 1200	
Received: D Brechele	<i>[Signature]</i>	10-17-1500	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.



3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

BF

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

MNY Workorder #

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:			PO#:		
Rush TAT Bus. Days:	2-5	5-7	Date Req.:		
Release to DOH:	Yes				
Email Results:	Yes				
Fax Results:	Yes				
	Email: <a href="mailto:rfilley@boces.com">rfilley@boces.com</a> / <a href="mailto:fhauck@boces.com">fhauck@boces.com</a>				

Sample Information			Analytix Requested			Receiving Info (Lab Use Only)		
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Container Material	Accepted?	YES NO
1 20-1	10/14	6:16	LS					YES NO
2 22-1		6:18						YES NO
3 21-1		6:17						YES NO
4 21-2		6:17						C W
5 19-1		6:15						YES NO
6 19-2		6:15						C W
7 23-1		6:19						YES NO
8 25		6:25						YES NO

Print Name and Company		Signature	Date/Time	Comments
Sampled:	LIAOA SHAO		10/17 12:00	
Received:	D Eschele		10-17/1500	
Received:				
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Ontario BOCES			Ice:	YES NO	YES NO	
Address:	20104 NYS Route 3			Cooler:	YES NO	YES NO	
Contact:	Watertown, NY 13601			Sample Temp:			
Phone:	Ray Filley			Cooler Seal:	YES NO		
Project:	315-779-7054			Pickup:	YES NO		
Quote ID:	Lead Testing			Dropoff:	C W		
Rush TAT Bur. Day:	2-5 5-7 7-10	PO#:		Accepted?	YES NO		
Release to DOH: Yes		Date Req.:		Container Material			
Email Results: Yes	filley@boces.com / fhack@boes.com			Container Size (in MI)			
Fax Results: Yes				Preservative			
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
1 944	10/14	7:27	LS	250			
2 955		7:30		HNO3			
3 966		7:30					
4 24-2		6:20					
5 20-2		6:16					
6 24-1		6:26					
7 23-2		6:19					
8 22-2		6:18					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: LINDA SHAW				10/17/01			
Received: P Breche				10/17/01			
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with that action.

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer, Onida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Ruth TAT Bur. Days:	2-5 5-7 7-10	Date Req.:	
Release to DOH: Yes			
Email Results: Yes	filley@boces.com / rfilley@boces.com		
Fax Results: Yes			
Sample Information			
Description/Location	Date	Time	Initial
56	10/14	721	LS
92		721	
88		721	
91		723	
90		723	
57		725	
89		723	
58		727	
Print Name and Company		Signature	Date/Time
LIAOA SHAO			10/17 1200
D. Brechele			10/17/1500
Received:			
Received:			
Received:			
Received:			
Received:			

Receiving Info (Lab Use Only)	Ice: YES NO
	Cooler: YES NO
Sample Temp:	
Cooler Seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO
Container Material	
Container Size (in MI)	
Preservative	
Comments/Field Data	

Analysis Requested	Number of Containers for Analysis Requested	Comments
200.8 Lead		
P		
250		
HNO3		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this practice.

3821 Buck Drive  
 Corland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY000936

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Yorktime-Onida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Ruth TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH:	Yes					Container Material	
Email Results:	Yes					Container size(In MI)	
Fax Results:	Yes					Preservative	
	filley@boces.com / fhawck@boces.com					Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1	8	10/14	712	CS			
2	11		716				
3	55		720				
4	93		724				
5	87		721				
6	59		724				
7	54		720				
8	86		721				
Print Name and Company				Signature		Date/Time	
Sampled: LIAOA SHAO						10/17 1200	
Received: D. Bechele						10-17/1500	
Received:							
Received:							
Received:							
Received:							
Received:							
Comments							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

3921 Buck Drive  
 Corland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10796, EPA #NY00936

**Microbac Laboratories, Inc. Samples must be returned on ice**  
**CHAIN OF CUSTODY**

BF

MNY Workorder #

Client Information				Billing/Invoice:			
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCCS							
Address: 20104 NYS Route 3							
Watertown, NY 13601							
Contact: Ray Filley							
Phone: 315-779-7054							
Project: Lead Testing							
Quote ID:				PO#:			
Rush TAT Bur. Days: 2-5 5-7 7-10				Date Req:			
Release to DOH: Yes							
Email Results: Yes				filley@boces.com / fhawck@boces.com			
Fax Results: Yes							

Sample Information				Analysis Requested				Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Container Material	Container size (in MI)	Preservative	Comments/Field Data
1 12	10/14	710	LS						
2 47		703							
3 84		719							
4 46		659							
5 50		718							
6 9		711							
7 51		718							
8 10		711							

Print Name and Company	Signature	Date/Time	Comments
Sampled: LIAOA SHAO		10/17 1200	
Received: D Bruchek		10-17-1500	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this subcontract.

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

BF

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Otsego BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Ruth TAT Bur. Days:	< 2-5 5-7 7-10	Date Req.:	
Release to DOH:	Yes		
Email Results:	Yes		
Fax Results:	Yes		
	filley@boes.com / ffilley@boes.com		

Sample Information		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested
1 5	10/14	707	LS		
2 16		708			
3 6		709			
4 1		603			
5 2		604			
6 80		704			
7 13		707			
8 97 109		710			

Accepted?	Container Material	Container Size (in MI)	Preservative	Comments/Field Data
YES NO				
YES NO				
C W				

Print Name and Company	Signature	Date/Time	Comments
Sampled: LINDA SHAW		10/17 1200	
Received: DJ Bechele		10-17-1000	
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this...

3821 Buck Drive  
Cortland NY 13045  
Phone:(607)753-3403 Fax:(607)753-3415  
NY #10795, EPA #NY00935

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

BF



MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES NO	Accepted?	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container Material	
Contact:	Watertown, NY 13601			Sample Temp:	YES NO	Container Size(In MI)	
Phone:	Ray Filley			Cooler Seal:	YES NO	Preservative	
Project:	315-779-7054			Pickup:	YES NO	Comments/Field Data	
Quote ID:	Lead Testing			Dropoff:	C W		
Rush TAT Bus. Days:	2-5 5-7 7-10						
Release to DOH:	Yes						
Email Results:	Yes						
Fax Results:	Yes						
	filley@boces.com / fhauck@boces.com						

Sample Information		Matrix		Number of Containers for Analysis Requested		Date/Time	
Description/Location	Date	Time	Initial	Type			
1 78	10/14	643	LS				
2 79		659					
3 81		707					
4 17		700					
5 82		710					
6 114		652					
7 15		708					
8 18		705					

Print Name and Company	Signature	Date/Time	Comments
Sampled: LINDA SHAW		10/17 1200	
Received: D. Stecher		10-15/1500	
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this condition.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY100935

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

BF

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckimer Oneida BOCES			Ice:	YES NO	Sample Temp:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	Cooler Seal:	YES NO
Contact:	Ray Filley			Pickup:	YES NO	Dropoff:	C W
Phone:	315-779-7054			Accepted?	YES NO	Container Material	
Project:	Lead Testing			Container size(in MI)		Preservative	
Quote ID:				Number of Containers for Analysis Requested		Comments/Field Data	
Rush TAT Bur. Days:	2-5 5-7 7-10						
Release to DOH:	Yes						
Email Results:	Yes						
Fax Results:	Yes						

Sample Information		Matrix		Type	
Description/Location	Date	Time	Initial	Matrix	Type
4	10/14	712	LS		
4B		703			
3		712			
83		711			
52		719			
85		720			
53		719			
14		707			

Print Name and Company	Signature	Date/Time	Comments
LIAOA SHAW		10/17/2001	
D. Bechele		10-17/1500	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this contract.