

Summary of Sampling

18 water samples were collected from 9 sources. All results are shown in Table 1.1.

Table 1.1

Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
M 1.01 FL	Hall by Traffic Office (194) - Left	DF - Drinking Fountain	First Draw	ND
M 1.01 SL	Hall by Traffic Office (194) - Left	DF - Drinking Fountain	Flush	ND
M 1.02 FR	Hall by Traffic Office (194) - Right	DF - Drinking Fountain	First Draw	ND
M 1.02 SR	Hall by Traffic Office (194) - Right	DF - Drinking Fountain	Flush	ND
M 1.03 FL	Hall by Restrooms (153/154) - Left	PDF - Drinking Fountain	First Draw	ND
M 1.03 SL	Hall by Restrooms (153/154) - Left	DF - Drinking Fountain	Flush	ND
M 1.04 FR	Hall by Restrooms (153/154) - Right	DF - Drinking Fountain	First Draw	ND
M 1.04 SR	Hall by Restrooms (153/154) - Right	DF - Drinking Fountain	Flush	ND
M 1.05 F	Teachers' Lounge	S - Sink	First Draw	8.52 ppb
M 1.05 S	Teachers' Lounge	S - Sink	Flush	2.90 ppb
M 1.06 F	Kitchen - North	KS - Kitchen Sink	First Draw	ND
M 1.06 S	Kitchen - North	KS - Kitchen Sink	Flush	ND
M 1.07 F	Kitchen - South	KS - Kitchen Sink	First Draw	3.28 ppb
M 1.07 S	Kitchen - South	KS - Kitchen Sink	Flush	ND
M 1.08 F	Hall by Front Entrance	DF - Drinking Fountain	First Draw	ND
M 1.08 S	Hall by Front Entrance	DF - Drinking Fountain	Flush	ND
M 1.09 F	Hall by Room 113	DF - Drinking Fountain	First Draw	ND
M 1.09 S	Hall by Room 113	DF - Drinking Fountain	Flush	ND
ND = None Detected				

*A drinking fountain, located in the Gym, was not sampled, as it was inoperable.

