

Vivian Teeter

From: Sam Reed <SamR@construct1.com>
Sent: Tuesday, August 29, 2017 7:00 AM
To: Vivian Teeter
Cc: Jon Archibald
Subject: FW: Kettle Education Center

Vivian

Please see Pre-Bid RFI from one of our glass and glazing subcontractors below.

Sam Reed
Estimator, QSP, CESSWI



2832 Walnut Avenue, Suite C
Tustin, CA 92780
Phone: (714) 259-5400
Fax: (714) 259-5406

From: Angie Cortez [mailto:acortez@huntingtonglazing.net]
Sent: Monday, August 28, 2017 4:13 PM
To: Sam Reed <SamR@construct1.com>
Subject: Kettle Education Center

Sam,

Can you please clarify and confirm the following:

1. For Exterior Storefronts, please confirm if to follow detail it call out for 2" x 6" Center Glazed Thermally Broken
2. For Interior Storefronts, please clarify if to use 2" x 4 1/2" per Detail 5 & 6/A62.4 or per Detail 11 & 14 to be 2" x 6" Center Glazed
3. For Exterior Storefronts, it call out for Thermally Broken, to achieve Thermally Broken it needs to have Insulated Glass, please confirm if to use 1/4" Solarban 60 Clear TP + 1/2" Air Space + 1/8" Clear TP 060 Clear PVB 1/4" Clear TP

Your early reply is highly appreciated

Thank you

Best Regards,

Angie

Estimator – Office #1



4800 S Huntington Drive, Los Angeles, CA 90032

Tel: 323-227-0305 Fax: 323-222-2782

New Email: acortez@huntingtonglazing.net

Response:

1. For Exterior Storefronts, see elevations on sheet A53.3 and details 7, 8, 9, 13 / A62.4. Yes Thermally Broken per Spec section 084410.
2. For Interior Storefronts, see elevations on sheet A53.2 and details 6, 8, 11, 14 / A62.4 - interior to be 2" x 4 1/2".
3. See section 08 44 10.2.2.G.7.c.3 - SolarBan 60.

Vivian Teeter, SVA Architects, Inc.

8/29/17