

P.O. Box 665 - 117 West Main Street
Hahira, GA 31632

Phone: 229-585-9018

E-mail:

mail@altmanbarrettarchitects.com



Letter of Transmittal

TO: Plan Holders

FROM: Travis Petitjean

DATE: 04/17/2018

SUBJECT: Addendum 3
Classroom Addition to
Valdosta Middle School

WE ARE SENDING YOU:

- Enclosed
- Prints
- Change order

2 Pages via EMAIL (including cover)

- Specifications

ENCLOSED:

<u>COPIES</u>	<u>DATE</u>	<u>DESCRIPTION</u>
1	04/17/2018	Addendum 3

Transmitted as checked below:

- | | |
|--|--|
| <input checked="" type="checkbox"/> For your use | <input type="checkbox"/> No exceptions taken |
| <input type="checkbox"/> As requested | <input type="checkbox"/> Exceptions noted |
| <input type="checkbox"/> For your information | <input type="checkbox"/> Resubmit |
| <input type="checkbox"/> For review & comment | |

REMARKS:

COPY : A+B File 17033 / A-1

[M:\17033 Valdosta Middle School Addition\Addenda\Addendum 3\Transmittal Add 3.doc]

P.O. Box 665
Hahira, GA 31632

Phone: 229-585-9018
E-mail:
mail@altmanbarrettarchitects.com



**CLASSROOM ADDITION TO
VALDOSTA MIDDLE SCHOOL
VALDOSTA, GEORGIA
ADDENDUM NO. 3
April 17, 2018**

REVISIONS TO THE SPECIFICATIONS:

None

REVISIONS TO THE DRAWINGS:

1. Sheets A4020:
 - a. Window Types C, D, and E:
 - i. Add the following note to each frame; "Utilize 6" deep storefront frame designed to meet local wind code requirements in accordance with Section 08410."

END