

August 25, 2015

Aedis Architects  
387 S. First St.  
San Jose, CA 95113

**Subject: NHUSD Kitchen Refrigeration Upgrades  
New Haven Unified School District  
Project No. 2015004**

**DSA File No. (n/a)  
DSA Application No. (n/a)**

ADDENDUM NO. 1

---

CHANGES AND/OR CLARIFICATIONS OF THE DRAWINGS AND SPECIFICATIONS ARE AS FOLLOWS:

**GENERAL:**

ITEM NO. 1.1:            BID DEADLINES

Revise:            Bid Opening is to be **10:00 am, Friday, September 4, 2015.**  
The location and all other requirements remain unchanged.

Clarify:            Please send all questions regarding this project as RFIs to the  
Architect no later than 12:00 pm, Wednesday, August 26,  
2015. The final addendum to this project will be issued no  
later than 10:00 am Tuesday, September 1, 2015.

ITEM NO. 1.2:            THERMOSTAT SETTINGS

Clarify:            Temperature alarm settings are to be set at 0 degrees for  
freezer units and 38-40 degrees for refrigerator units.  
Coordinate further requirements with District.

ITEM NO. 1.3:            ELECTRICAL CONDUIT

Clarify:            Per section 26 05 33 part 3.01, all exterior electrical conduit  
is to be rigid metal. All exposed interior conduit below 6 feet  
above floor level is to be rigid metal. All interior conduit  
exposed above 6 feet above floor level or concealed is to be  
EMT. See also General Note 2 on sheet E2.1.

Attachments:  
None