



Dennis Township Board of Education
601 Hagen Road
Cape May Court House, NJ 08210
Attn: John McGroarty

Sample # Q1999
Sample Received: 4/17/2017
Sampled by: James Eberts (Epic Env.)

Dennis Twp Elementary/Middle School
165 Academy Road, Dennisville, NJ 08214

CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	FD / FL	Lead ug/L	Date Analyzed	Time Analyzed
Q1999-1	01DTES-WC-CH1	4/15/2017	10:07	FD	<2	4/18/2017	12:17
Q1999-2	03DTES-NS-CH2	4/15/2017	10:09	FD	<2	4/18/2017	12:20
Q1999-5	05DTES-WC-CH3	4/15/2017	10:11	FD	<2	4/18/2017	12:24
Q1999-7	07DTES-WC-CH4	4/15/2017	10:12	FD	<2	4/18/2017	12:28
Q1999-9	09DTES-TLS-AH5	4/15/2017	10:14	FD	<2	4/18/2017	12:31
Q1999-11	11DTES-WC-AH6	4/15/2017	10:15	FD	<2	4/18/2017	12:35
Q1999-13	13DTES-WC-AH7	4/15/2017	10:17	FD	<2	4/18/2017	12:38
Q1999-15	15DTES-FP-K8	4/15/2017	10:19	FD	<2	4/18/2017	13:55
Q1999-17	17DTES-IM-K9	4/15/2017	10:21	FD	<2	4/18/2017	13:59
Q1999-18	18DTES-WC-BH10	4/15/2017	10:22	FD	<2	4/18/2017	14:03
Q1999-20	20DTES-DW-BH11	4/15/2017	10:24	FD	6.4	4/18/2017	14:06
Q1999-22	22DTES-WC-BH12	4/15/2017	10:26	FD	2.4	4/18/2017	14:10
Q1999-24	24DTES-WC-BH13	4/15/2017	10:27	FD	<2	4/18/2017	14:14
Q1999-26	26DTES-DW-BH15	4/15/2017	10:28	FD	2.9	4/18/2017	14:17
Q1999-28	28DTES-DW-AH16	4/15/2017	10:32	FD	<2	4/18/2017	14:21
Q1999-30	30DTES-WC-DH17	4/15/2017	10:35	FD	<2	4/18/2017	14:24

Note: FD represents First Draw and FL represents Flushed sample


Latish Mengham
Laboratory Director