

RFI

Today's Date: 8/29/2017

RFI #: 03

From: Post Earthworks

To: Construct One

Information Requested: Slot cutting against existing building

The proposed hard scape around the building is to be over excavated 4 feet. Are we to anticipate slot cutting against the building?

Response:

Yes contractor needs to perform the over-excavation in slots to reduce the potential for damage on adjacent structures.

Raul R. Garcia, PE, GE | Senior Engineer
Geocon Incorporated
8/30/174