

Vivian Teeter

From: Sam Reed <SamR@construct1.com>
Sent: Tuesday, August 29, 2017 9:31 AM
To: Vivian Teeter
Cc: Jon Archibald
Subject: District Education Center Renovation Pre-Bid RFI Steel

Vivian

RFI question from one of our steel subcontractors.

The bent plate wall opening frames det. 2/S303 indicates typical at new opening. On sheet S112 grid line 12 between E-F It looks like there are 4 openings. And between G-H there looks like 4 openings also. Does this detail apply to all these openings?

Sam Reed
Estimator, QSP, CESSWI



2832 Walnut Avenue, Suite C
Tustin, CA 92780
Phone: (714) 259-5400
Fax: (714) 259-5406

Response:

It's one big opening between E and F and between G and H. Yes, these are new openings and require detail 2/S-303, however, each side of the opening is an existing concrete pilaster, so the bent plate is only required at the top of the opening.

SG, Petra Structural Engineers
8/29/17