

Tooele County School

10/24/2017

LEAD IN WATER

	School	Schools tested for lead	Lead Level in Sink	Lead Level in Drinking Fountain	Units	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit
1	Anna Smith Elementary	x	0.0007	ND	mg/L	0.015	0.0005
2	Copper Canyon Elementary	x	0.0037	ND	mg/L	0.015	0.0005
3	Community Learning Center	x	0.0049	ND	mg/L	0.015	0.0005
4	Clarke N. Johnsen Jr. High	x	0.0042	0.0005	mg/L	0.015	0.0005
5	Sterling	x	0.0034	ND	mg/L	0.015	0.0005
6	Old Mill	x	0.0041	ND	mg/L	0.015	0.0005
7	Early Learning Center	x	0.0047	0.0055	mg/L	0.015	0.0005
8	Grantsville Elementary	x	0.0029	ND	mg/L	0.015	0.0005
9	Grantsville High	x	0.0045	0.0017	mg/L	0.015	0.0005
10	Grantsville Jr High	x	0.0061	0.0029	mg/L	0.015	0.0005
11	Ibapah Elementary	x	0.0022	ND	mg/L	0.015	0.0005
12	Middle Canyon Elementary	x	0.0029	0.0009	mg/L	0.015	0.0005
13	Northlake Elementary	x	0.0035	ND	mg/L	0.015	0.0005
14	Overlake Elementary	x	0.0039	0.0008	mg/L	0.015	0.0005
15	Rose Springs Elementary	x	0.0047	ND	mg/L	0.015	0.0005
16	Stansbury Park Elementary	x	0.0031	ND	mg/L	0.015	0.0005
17	Stansbury High School	x	0.0024	ND	mg/L	0.015	0.0005
18	Settlement Canyon Elementary	x	0.0032	0.0007	mg/L	0.015	0.0005
19	Tooele High School	x	0.0022	ND	mg/L	0.015	0.0005
20	Tooele Jr. High	x	0.0023	0.004	mg/L	0.015	0.0005
21	Vernon Elementary	x	NA	0.0005	mg/L	0.015	0.0005
22	Wendover High	x	0.0018	ND	mg/L	0.015	0.0005
23	West Elementary	x	ND	0.0096	mg/L	0.015	0.0005
24	Willow Elementary	x	0.0016	0.0006	mg/L	0.015	0.0005
25	Dugway High School	x	0.0044	ND	mg/L	0.015	0.0005

Footnotes

ND = Not detected at the corresponding Minimum Reporting Limit NA= Not available

1 mg/L = one milligram per liter or 1mg/K = one milligram per kilogram = 1 part per million