

# ROSEBUD-LOTT INDEPENDENT SCHOOL DISTRICT

*Steven Brownlee, Ed.D.*  
Superintendent of Schools

---

Campus: Rosebud-Lott High School  
Date : November 30, 2017  
Submitted by: Robby Sims  
Contact Information: 254-583-1917 or [rsims@rlisd.org](mailto:rsims@rlisd.org)

**Deficiency** – The Texas Commission on Environmental Quality (TCEQ) has notified the Rosebud-Lott ISD TX0730025 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter(mg/L) based on locational running annual average(LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three of 2017 of 0.097 mg/L for DBP2-02 and 0.096mg/L for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about this may affect you.

**Corrective Action** – Rosebud-Lott ISD maintenance department has begun frequent flushing of all water lines located at the High School campus on a regular basis through out the school year and summer months.