



# Garden State Laboratories, Inc.

Bacteriological and Chemical Testing  
410 Hillside Avenue  
Hillside, New Jersey 07205



Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director

### REPORT OF ANALYSIS

Toll Free 800-273-8901  
Telephone 908-688-8900  
Fax 908-688-8966  
email: info@gslabs.com  
Internet: www.gslabs.com

REPORT # 360316039.0

CLIENT # SCI09

DATE SUBMITTED: 3/16/16

TO: Scientific Water Conditioning  
515 Pennsylvania Ave.

Linden

NJ 07036

ATT: Andrew Lewin

SAMPLE TYPE: DRINKING WATER; GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: WATER FOUNTAIN - ST. BERNARDS SCHOOL, 368 SOMMER AVE., PLAINFIELD, NJ 07062

DATE SAMPLED: 3/16/16

TIME SAMPLED: 14:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	3/21/16

< = less than, not detected.  
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

294429

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.