

# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Fullerton, City of  
303 W. Commonwealth Ave.  
Fullerton CA, 92832

Project: School Lead Program  
Sub Project: Lead Sampling for FSD / Nicolas Jr. High  
Project Manager: Louis Gonzalez

Work Order: 18B0794  
Received: 02/08/18 16:25  
Reported: 02/16/18

3010010-ABI-A 18B0794-01 (Water) Sample Date: 02/08/18 6:07 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 02/14/18 02/14/18 1807059

3010010-ABI-B 18B0794-02 (Water) Sample Date: 02/08/18 6:15 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 02/14/18 02/14/18 1807059

3010010-ABI-C 18B0794-03 (Water) Sample Date: 02/08/18 6:23 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 02/14/18 02/14/18 1807059

3010010-ABI-D 18B0794-04 (Water) Sample Date: 02/08/18 6:35 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 02/14/18 02/14/18 1807059

3010010-ABI-E 18B0794-05 (Water) Sample Date: 02/08/18 6:45 Sampler: Ronnie Acosta

Analyte	Method	Result	Rep. Limit	Action Level	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	--------------	-------	----------	----------	-------	-----------

Metals

Lead (Pb) SM3113-B ND 5.0 15 ug/L 02/14/18 02/14/18 1807059

ND Analyte NOT DETECTED at or above the reporting limit

Stu Styles  
Client Services Manager

# Clinical Laboratory of San Bernardino, Inc.

## EDT Transfer Confirmation 1



Work Order: 18B0794

Report Date: 02/16/2018

Analyzing Lab: Clinical Laboratory of San Bernardino, Inc. ELAP 1088

CITY OF FULLERTON		User ID: TEE	System: 3010010
Nicolas Junior High-Partition 3 Drinkin	Station No.: 3010010-ABI-A	Sampled: 180208 06:07	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051 Analyzed: 180214
Nicolas Junior High-Partition 4 Drinkin	Station No.: 3010010-ABI-B	Sampled: 180208 06:15	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051 Analyzed: 180214
Nicolas Junior High-Partition 7 Drinkin	Station No.: 3010010-ABI-C	Sampled: 180208 06:23	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051 Analyzed: 180214
Nicolas Junior High-Partition 5 Drinkin	Station No.: 3010010-ABI-D	Sampled: 180208 06:35	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051 Analyzed: 180214
Nicolas Junior High-Partition 5 Drinkin	Station No.: 3010010-ABI-E	Sampled: 180208 06:45	
LEAD	Result: ND	Units: UG/L	Entry No.: 01051 Analyzed: 180214

# Clinical Lab of San Bernardino, Inc.

# Chain of Custody

21881 Barton Road Grand Terrace CA 92313 909 825-7693 / Work Order: \_\_\_\_\_

18B0794

Client		City of Fullerton		Destination Laboratory		Analysis Requested										Comments	Date/Time (TAD)									
Address:		303 West Commonwealth Ave. Fullerton, CA 92832		<input checked="" type="checkbox"/> Clinical Grand Terrace / ELAP 1088																						
Client Contact: Jon Orndorff				Report Options												Lead SM 3113B										
Phone No.: (714) 738-6746		FAX No.: (714) 738-3115		<input checked="" type="checkbox"/> Hardcopy   <input type="checkbox"/> Client Connect																						
System No.: 3010010				<input checked="" type="checkbox"/> Email																						
Project: Lead Sampling for FSD																										
Sub Project: Nicolas Jr. High																										
Sampled By: <i>Ronnie Acosta</i>																										
Date	Time	Sample Identification	Container ID	Matrix	Sample Type	Unpreserved	NH4Cl	CH806	HNO3	HCl	NaOH	Na2SO3	ZnCl2/04	Total Counters												
2/8/2018	6:07	3010010-ABI-A	1	DW		1								1	X											7
2/8/2018	6:15	3010010-ABI-B	2	DW		1								1	X											7
2/8/2018	6:23	3010010-ABI-C	3	DW		1								1	X											7
2/8/2018	6:35	3010010-ABI-D	4	DW		1								1	X											7
2/8/2018	6:45	3010010-ABI-E	5	DW		1								1	X											7
			6	DW																						7
			7	DW																						
			8	DW																						
			9	DW																						
			10	DW																						
			11	DW																						
			12	DW																						
			13	DW																						
			14	DW																						
			15	DW																						

Matrix: DW - Drinking Water GW - Ground Water SW - Surface Water W - Water WW - Wastewater SWR - Stormwater Runoff S - Sludge O - Other  
 Use for Bacteria Samples / Sample Type: 1-Routine 2-Repeat 3-Replacement 4-Special D-Distribution W-Well TAT: (10) Ten Day (5) Five Day Rush (2) Two Day Rush

Relinquished By (Sign)	Print Name / Company	Date / Time	Received By (Sign)	Print Name / Company
<i>Ronnie Acosta</i>	Ronnie Acosta/COF	2-8-18 7:00am	<i>Michael Salazar</i>	Michael Salazar/CLSB
		2-8-18 1:33	<i>Mike</i>	Mike/CLSB
<i>Michael Salazar</i>	Michael Salazar/CLSB	2/14/25	<i>[Signature]</i>	RHWS/CLSB

Condition:  On Wet Ice  On Blu Ice  Intact  Custody Seals Samples / COE Checked By: \_\_\_\_\_

Receipt Comments: \_\_\_\_\_ Clinical Lab Receipt Temp.: 7.7 °C